

OFFICE OF THE **DIPHU MUNICIPAL BOARD**  
**KARBI ANGLONG, DIPHU, ASSAM**



No. DMB/W/S/214

Date : 20/07/2023

**PROFORMA REGARDING SAFE DRINKING WATER**  
**AND SANITARY CONDITION CERTIFICATE**

It is certified that an inspection team headed by Mr. Pradeep Rongpi, Asst. Engineer, from Diphu Municipal Board Office, Diphu, Karbi Anglong, Assam inspected the ERUDITE ACADEMY, Diphu Town, Karbi Anglong, Assam on 20-07-2023 and found that the ERUDITE ACADEMY has safe drinking water facilities (the test report of the water is attached herewith) for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the State Government of Assam.

The above is valid for a period of 3 years from the date of issue.

*Pradeep Rongpi*  
20/7/2023  
Asst. Executive Engineer  
Diphu Municipal Board  
Karbi Anglong  
Asst. Engineer (DMB)

**Karbi Anglong District, Diphu**

**District Level Laboratory**  
**Address: Office of the Executive Engineer (PHE), Diphu**  
**Division: Diphu (Rural)**



**Test Report**

Test Report No.: **Diphu /DLL(R)/ 2023 – 24/476**

Issue Date: **25/07/23**

ULR NO: TC1068223000000356F

Issued To: Mahananda Haflongha

Sample received on dated: 20/07/23

Sample Description: Drinking Water

Sample Location: **ERUDITE ACADEMY, DIPHU**

Vill: Ward no. 5, Diphu

Quantity: **1 ltr**

Sample Type: Ring Well (Raw Water)

Date of Analysis started: 21/07/23

Sample collected on dated: 20/07/23

Date of Analysis Complete: 21/07/23

Sample collected by: Mahananda Haflongha

Sl. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	pH	IS: 3025: Part 11 @ 25 °C	6.97	6.5 – 8.5	No relaxation	PH Units
2	Turbidity	IS: 3025: Part 10	0.8	1	5	NTU
3	Iron	APHA 3500- Fe B	0.03	0.3	No relaxation	mg/L
4	Chloride	IS: 3025: Part 32	17.016	250	1000	mg/L
5	Total Hardness	IS: 3025: Part 21	24	200	600	mg/L
6	Total Alkalinity	IS: 3025: Part 23	12	200	600	mg/L
7	Fluoride	APHA 4500-F <sup>-</sup> D IS: 3025 (Part 60)	0.62	1.0	1.5	mg/L
8	Total dissolved Solids (TDS)	IS : 3025 : Part 16	13.01	500	2000	mg/L
9	Calcium	IS:3025: Part 40	-	75	200	mg/L
10	Sulphate	IS:3025:Part 24	-	200	400	mg/L
11	Magnesium	APHA 3500-Mg B	-	30	100	mg/L

**Opinion: The Parameter Tested at Sl. No.    In the test report does not meet the requirement of IS 10500:2012 (Second Revision)**  
**Notes:**

1. The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sender.
2. The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
3. The test report cannot be used for any publicity or any legal purpose.
4. The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.
5. All tests are performed at temperature  $25 \pm 2$  °C and humidity  $55 \pm 10$  %.

**Reviewed By: Quality Manager**

  
**Authorized Signatory: Quality Manager**  
**(Privadarshini Devi)**  
**Quality Manager**  
**Diphu DLL (PHED)**

.....END OF TEST REPORT.....